



**Purchasing Department
113 Mable T. Willis Blvd.
Walterboro, SC 29488
843.782.0504**

**BID: FM-52
SEWER PUMP STATION AND FORCE MAIN
AT THE
COLLETON COUNTY CAREER SKILLS CENTER**

Due: Wednesday, January 29, 2020 @ 11:00am

**ADDENDUM 2
DATED: JANUARY 23, 2020**

The following questions have been submitted for clarification:

- 1) The lid drawing shows the diameter of the wet well to be 5', but the specifications state 8'. Which dimension is correct? **Answer:** The diameter of the wet well is 5'.