


<b>COLLETON COUNTY, SOUTH CAROLINA,</b> a body politic and corporate and a political subdivision of the State of SC	MAIL TO: Finance-Purchasing ATTN: Mr. Deron Smith PO Box 157 Walterboro, SC 29488	
<p style="text-align: center;"><b>AMENDMENT #4</b> <b>SEALED BEST VALUE BID</b></p>	HAND CARRY TO: Purchasing Office, Room 208A Harrelson Building, 31 Klein Street Walterboro, South Carolina 29488	
<p style="text-align: center;"><b>Proposals will be accepted until 2:00 PM, Tuesday, June 8, 2010</b></p> <p style="text-align: center;">-----</p> <p style="text-align: center;"><b>A MANDATORY Pre-Proposal Conference will be held Tuesday May 25, 2008 at 2:00 PM</b></p>	TELEPHONE NO. (843) 549-5716	
Then Publicly Opened in Room 208	<b>PROPOSAL NUMBER: FM-27 Baseball Quadrangle Design and Construction</b>	

**AMENDMENT #4**

**FM-27 Baseball Quadrangle Design and Construction**

**This amendment is effective May 24, 2010.**

Sealed Best Value Bid FM-27 must be further revised and clarified for additional specifications regarding the desired irrigation system.

1. The grass areas of the fields shall be irrigated in a 10 hour per day watering window that will apply 1 ½" of precipitation in a 7 day time frame.
2. Well specifications:
  - a. The proposed irrigation system should include 2 wells, 6 inches in diameter for the purposes of watering the grass areas of the 4-ball field quadrangle.
  - b. For Alternate Bid #1: There should be one well, 4 inches in diameter for the purposes of watering the grass areas of the multi-purpose field.
3. The wells are to be operated by variable frequency drive controllers. At ground level each 6" well is to supply a minimum continuous discharge of 70 gpm at 70 psi. Larger wells are acceptable if all of the criteria for the irrigation system are met.
4. Sprinkler heads are to be 1" inlet, rubber covered and specifically designed for sports field use. Sprinklers are to be spaced to throw head to head at a maximum of 55 feet apart and are to apply water at a minimum precipitation rate of 0.40 in/hr. Sprinklers are to be part and full circle operation in a single rotor and have a 5 year warranty.