



COLLETON COUNTY
SOUTH CAROLINA

Purchasing Department
113 Mable T. Willis Blvd.
Walterboro, SC 29488
843.782.0504

BID: CPST-13
Tax Payer Service Center

Due: Thursday, February 18, 2021 at 11:00am

ADDENDUM 2

DATED: February 16, 2021

Please see the correction to the following questions listed in Addendum #1 dated February 11, 2021 and time change to bid.

28. Question: Is this is a Davis bacon wage job? **Answer:** Yes
33. Question: Please confirm this IS NOT a Prevailing Rate project. **Answer:** This is not a prevailing rate project.

Correct Answer for #28 and #33: See Article 12 - Preparation of Bid, for any applicable LAWS or ACTs. If a certain LAW or ACT is not listed than it is not required.

36. Question: The thickness or R-Value of the rigid insulation for the roof system is not specified. Please specify. **Answer:** All roof insulation is to be R38.

Correct Answer: Roof insulation is R20 per Specification Section 07 21 00 Thermal Insulation, paragraph 2.03.B.

Due: Thursday, February 18, 2021 at 11:00am

Time change - Due: Thursday, February 18, 2021 at 2:00pm