



Capital Projects & Purchasing Department
113 Mable T. Willis Blvd.
Walterboro, SC 29488
843.539.1968

BID: FM-50
CARPET REPLACEMENT AT COURTHOUSE

DUE: Tuesday, August 28, 2018 @ 11:00am

Addendum #2
dated 8-14-2018

The following questions have been submitted for clarification:

- Question 1: Addendum 1 has *Area 202* highlighted for carpet. Is this area to be carpeted?
Answer: No, stop carpet at doorway.
- Question 2: Addendum 1 does not have *Area 138* highlighted, which has carpet that matches Area 137. Do you want the carpet in this area?
Answer: Yes, it is 6'3" long x 5' wide.
- Question 3: Addendum 1 says carpet the judge's steps, which can be done but will need metal or rubber nosing to be installed on them, is this approved?
Answer: No. Carpet should be used in all locations. If squares will not work, roll carpet of the same color shall be provided.
- Question 4: Do you want Attic Stock, and if so how much Attic stock would you want?
Answer: Yes, four (4) boxes.
- Question 5: Addendum 1 says to use the same carpet specifications as the Broadloom. This spec. is not available in a carpet tile format. Can you please change the specifications to fit a carpet tile?
Answer: Carpet Tile Specification
- Construction: Textured Patterned Loop
 - Color: To be determined by Owner
 - Fiber Content: nylon
 - Dye Method: Yarn/Solution Dyed
 - Yarn Weight: 20oz/yd²
 - Gauge: 1/12 in
 - Pile Height: .112 in
 - Primary Backing: 100 percent Woven Synthetic
 - Secondary Backing Reinforced Composite Closed Cell Polymer
 - Standard Size: 24 by 24 inches