


COLLETON COUNTY, SOUTH CAROLINA, a body politic and corporate and a political subdivision of the State of SC	MAIL TO: Finance-Purchasing ATTN: Kaye B Syfrett PO Box 157 Walterboro, SC 29488	
SEALED BEST VALUE BID	HAND CARRY TO: Purchasing Office, Room 208 Harrelson Building, 31 Klein Street Walterboro, South Carolina 29488	
Bids will be accepted until 11:00AM, Thursday, June 6, 2013	TELEPHONE NO. (843) 782-0504	
Bid opening will be held at Council Chambers located at 109 Benson Street, Walterboro	BID NUMBER: FR-16 Construction of a Fire/Rescue Substation for Ions Crossroads	

Addendum #3

This addendum is dated 6-4-2013

1. Excavated fill for the retention area and areas after organics shall remain on site and be graded through-out site.
2. Contractor to provide cost for geo-fabric material and installation in bid as recommended by the Soils Report. ADD line item in Bid form for Geo-fabric square yard. (Installation included.)
3. SEE REVISED CIVIL DRAWING TO REFLECT THE SOILS REPORT.
 - a. Added sub grade drains underneath the pavement.
 - b. Added a construction detail for the sub grade drains
 - c. Added 4" of crushed aggregate base course under the 8" of concrete paving
 - d. Changed the plan date to 6/3/2013.
4. Specifications: 8700 Door Hardware-2.1-B, 1 DELETE "BY GRAINGER."
5. Specification: 8700 Door Hardware-2.1-B change to A- Series / Grade 2 Cylindrical lock-storeroom lock-lever
6. Wind Load is between 120 mph and 110mph. Use 120 MPH.
7. The utility company, Coastal Electric Cooperative, Inc., will furnish and bury the underground service conductors and furnish the meter can. Contractor to provide \$150.00 underground service charge fee in Bid.
8. Add line item of sub grade drains- Lin ft. (installation included in Lin ft.)